

Hello,

Customer: This is strictly for your information. An application has been approved on your behalf from the addressed installer. We do not require anything from you at this time.

Installer:

NOTE: The billing meter will be provided with a height variance. The disconnect and production meter must be installed at standards height of 60-72 inches.

A Solar Energy system was approved for SOTO at 1611 WOOD AVE on 2023-05-09. Below are the application details:

1. No. of panels= 16
2. PTC panel rating(Watts) = 397.9
3. Non panel system losses =0.4
4. System size AC kWatts = 4.4
5. Energy Storage System Included = no
6. Energy Storage System Capacity kWh = 0
7. Contractor = SunPower Energy, contact Miguel Silva,



Colorado Springs Utilities has reviewed the application for general conformance with Utilities' Electric Line Extension and Service Standards, including existing meter height, meter locations and renewable energy system sizing. Additional electrical review for National Electric Code and Pikes Peak Regional Building Code compliance will be performed by Pikes Peak Regional Building Department.

Respectfully,

Elizabeth Ritchey | Engineer III
Colorado Springs Utilities | Solar Energy Program
PO Box 1103, MC 1339
Colorado Springs CO 80947
719.668.8509

CONFIDENTIALITY NOTICE - This email transmission, and any documents, files or previous email messages attached to it, may contain information that is legally privileged or otherwise confidential to include customer and business information. If you are not the intended recipient, or an authorized person for the intended recipient, you are hereby notified that any disclosure, copying or distribution of this information, or any action taken in reliance on the information contained within this email, is strictly prohibited. If you have

received this email message in error, please notify the sender and then delete the message (and any attachments) from your computer and/or network. Thank you.